

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

### CB TEST CERTIFICATE

Product

Fuse-disconnector

Name and address of the applicant

Mersen France SB S.A.S.  
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE  
FRANCE

Name and address of the manufacturer

Mersen France SB S.A.S.  
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE  
FRANCE

Name and address of the factory

Mersen France SB S.A.S.  
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE MURE  
FRANCE

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Additional Information on page 2  
Ie: 32A; Ue: 400V a.c./d.c.  
Ie: 16A; Ue: 690V a.c.  
AC-20B / DC-20B; size: 10 x 38

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CMC10 series / CUS10 series

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007; 60947-1:2007/AMD1:2010  
IEC 60947-1:2007/AMD2:2014  
IEC 60947-3:2008; 60947-3:2008/AMD1:2012  
IEC 60947-3:2008/AMD2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

249846-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH  
VDE Testing and Certification Institute  
Zertifizierung Produkte / Certification Products

Date: 2018-08-29

Signature:

R. Nickel