

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fuse-disconnector

Name and address of the applicant

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE
MURE
FRANCE

Name and address of the manufacturer

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE
MURE
FRANCE

Name and address of the factory

Mersen France SB S.A.S.
15 Rue Jacques de Vaucanson, 69720 SAINT BONNET DE
MURE
FRANCE

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

le: 25A; Ue: 400V a.c.; AC-20B; size: 8 x 32

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CMC8 series

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007
IEC 60947-1:2007/AMD1:2010
IEC 60947-1:2007/AMD2:2014
IEC 60947-3:2008; IEC 60947-3:2008/AMD1:2012
IEC 60947-3:2008/AMD2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

249845-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-08-29

Signature:

R. Nickel